



STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
& ENVIRONMENTAL CONTROL
DIVISION OF WATER RESOURCES
422 N. DuPont Highway, Suite 1
Georgetown, Delaware 19947

TELEPHONE: (302) 856-4561
FAX No.: (302) 856-5088

*Please sink
all staff the
Dor*

January 17, 2006

Fralo/Plastech
Attn: Joseph A. Brown P.E.
1 General Motors Drive
Syracuse, NY 13206

RE: Use of Fralo/Plastech tanks as pump chambers or dosing chambers.

Dear Mr. Brown,

The Department is in receipt of a report and approval letter, from John O'Connell PE, for the use of Fralo/Plastech tanks as pump tanks and/or dosing chambers.

Considering his report and accompanying documentation the Department is pleased to approve the ST-500, ST-750, ST-900, ST-1000, ST-1060, ST-1250 and ST-1500 tanks for use as pump tanks and/or dosing Chambers in Delaware. Additional calculations may be required for the use of the ST-500, as it may not meet storage capacity requirements, for dosing chambers, in some cases.

The "Fralo Tank Anchoring Manual" should be forwarded to all Class E licensed installers and Class C licensed Engineers as they will be the most effected during the construction and inspection phases of the of the project. The manual should also be made available through the distributors of the product and on line.

Additionally, as the internal divider in the tank is an integral part of the tank and should not allow flow to move between the tanks compartments. It will be necessary to create openings in the internal divider to allow equalization of the tank compartments for dose sizing purposes.

Delaware's good nature depends on you!

In the event that the design, construction, or materials used in the manufacturing of the tanks should change, re-approval by the Department will be required.

Please feel free to contact the Ground Water Discharges Section if you have any questions at 1-302-739-4761.

Sincerely,

A handwritten signature in black ink, appearing to read "Jim Cassidy", written over the printed name.

James Cassidy
Program Manager I
Ground Water Discharges Section