



K A N S A S

RODERICK L. BREMBY, SECRETARY

DEPARTMENT OF HEALTH AND ENVIRONMENT

KATHLEEN SEBELIUS, GOVERNOR

October 19, 2004

Mr. Mark Jones, P.E.
FRALO Plastech
One General Motors Drive
Syracuse, NY 13206

RE: Certification for FRALO Plastech SEPTECH Models ST-750 (750 gallon),
ST-1060 (1,060 gallon), ST-1250 (1,250 gallon) and ST-1500 (1,500 gallon)

Dear Mr. Jones:

I have received the certification for the above referenced septic tanks manufactured by FRALO Plastech. The certification by Harlan D. Foraker, P.E., Kansas Professional Engineer License #10891, confirms that your tanks meet the requirements of the state of Kansas.

During my telephone conversation today with Dan Hodes, Hodes & Sutter, Inc., he agreed to provide a letter embossed with Mr. Foraker's engineering seal. We look forward to receiving this by November 1, 2004.

We encourage you to provide training to contractors installing the tanks to ensure proper installation and maintenance and the continued integrity of the tank. We would also like to remind you to keep us updated if your product line changes.

Thank you for your assistance in protecting water quality in Kansas.

Sincerely,

Donald D. Snethen P.E.
Chief, Watershed Management Section
Bureau of Water

pc: Harlan D. Foraker, P.E.
Dan Hodes, Hodes & Sutter, Inc.
KDHE-District Offices

Be a clean water neighbor.

DIVISION OF ENVIRONMENT
Bureau of Water - Watershed Management Section
CURTIS STATE OFFICE BUILDING, 1000 SW JACKSON ST., STE 420, TOPEKA, KS 66612-1367
Voice 785-296-4195 Fax 785-296-5509 <http://www.kdhe.state.ks.us>



K A N S A S

RODERICK L. BREMBY, SECRETARY

KATHLEEN SEBELIUS, GOVERNOR

DEPARTMENT OF HEALTH AND ENVIRONMENT

May 4, 2006

Mr. Dan DeLawyer
Fralo Plastech Mfg.
One Genral Motors Drive
Syracuse, NY 13206

RE: Creep or deformation of the Fralo ST-1000E

Dear Mr. DeLawyer:

I am pleased to acknowledge receipt of a statement from Harlan D. Foraker, Kansas Professional Engineer, 10891, attesting that the Fralo ST-1000E wastewater tank will not under the loading conditions stipulated by Kansas Bulletin 4-2, Minimum Standards for Design and Construction of Onsite Wastewater Systems deform or creep more than five percent.

Please contact me if you have questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Donald D. Snethen".

Donald D. Snethen, P.E., Chief
Watershed Management Section

Pc: Harlan Foraker