



STATE OF WEST VIRGINIA
DEPARTMENT OF HEALTH AND HUMAN RESOURCES

Bob Wise
Governor

October 20, 2003

Paul L. Nusbaum
Secretary

Mr. Mark Jones, PE
Technical and Regulatory Manager
Fralo Plastech Manufacturing, LLC
One General Motors Drive
Syracuse, NY 13206

Dear Mr. Jones:

Our Department has reviewed your submission for approval of the Fralo Septech polyethylene septic tanks listed below:

FRALO MODEL

LIQUID CAPACITY

ST-750	750 Gallons
ST-1060	1,060 Gallons
ST-1250	1,250 Gallons
ST-1500	1,500 Gallons

The above tanks are approved for use in West Virginia provided the ST-750 will be approved for use **only if** it is installed in series after a 1,000 gallon septic tank or for use as a pump chamber.

WV CSR 64, Series 47 also requires that a four (4) inch inspection port be installed to final grade for inspection purposes. Polyethylene tanks have been given an option of installing this port via a hole sawn into the top of the tank followed by the installation of a riser that extends to the surface at final grade, or by the installation of the inspection port into the lid of the riser and then extended to the surface at final grade.

This approval of these septic tanks for use in West Virginia will be distributed to local health departments and district offices.


This approval does not in any way constitute an endorsement of your products. This office reserves the right to rescind this approval if conditions warrant.

BUREAU FOR PUBLIC HEALTH
Office of Environmental Health Services
Public Health Sanitation Division
815 Quarrier Street, Suite 418 (Morrison Building) Charleston, West Virginia 25301-2616
Telephone: (304) 558-2981 FAX: (304) 558-1071

Mr. Mark Jones, PE
October 20, 2003
Page Two

Should you have any questions or comments about this approval, please contact Mark Whittaker, R.S. at (304) 367-2752 or myself.

Sincerely,



Joseph A. Wyatt, Acting Director
Public Health Sanitation Division

JAW/MW/dg

cc: Public Health Sanitation Division Staff
Local Health Departments
District Offices
Mark Whittaker, R.S.



STATE OF WEST VIRGINIA
DEPARTMENT OF HEALTH AND HUMAN RESOURCES
BUREAU FOR PUBLIC HEALTH
OFFICE OF ENVIRONMENTAL HEALTH SERVICES

April 21, 2005

Joe Manchin III
Governor

Martha Yeager Walker
Secretary

Dan DeLawyer, Product Manager
Fralo Plastech
One General Motors Drive
Syracuse, New York 13206

Dear Mr. DeLawyer:

Your request for approval of the Fralo Plastech Septech™ model ST-1000 E septic tank has been received and the tank has been evaluated in accordance with the "Sewage Treatment and Collection System Design Standards" (64 CSR 47)

The Fralo Plastech Septech™ model ST-1000 E tank has been approved for use as a septic tank in West Virginia contingent on the following:

1. The top of each tank, above the outlet, shall have embossing, imprinting, stenciling or other form of marking in an indelible and legible manner with the manufacturer's name, the liquid capacity and date of manufacture. (64CSR47 6.4.g.8.)
2. The tanks shall have constructed, on installation, a four (4) inch gas tight inspection port that extends to the surface of the ground to measure sludge and scum accumulation or have the manhole riser extend to the surface of the ground to facilitate the measurement of the sludge and scum accumulations. (64CSR47 6.4.g.10)

The approval of the above named unit does not constitute an endorsement of your product. The Public Health Sanitation Division reserves the right to rescind this approval should conditions warrant. Should you have any questions please feel free to contact me at (304) 558-6730.

Sincerely,

Joseph A. Wyatt, Acting Director
Public Health Sanitation Division